



Fire Test Certificate

This is to certify that the specimen described below has been examined by BRANZ Ltd on behalf of

ASSA ABLOY Australia Pty Ltd
235 Huntingdale Road
Oakleigh, Victoria 3166
Australia

Test standard: AS 1530.4:2014 with reference to AS 1905.1:2015 and NZS 4520:2010

Specimen name: KAS hardware on Pyropanel FR doorsets

Specimen description: KAS hardware installed on nominal 38 mm and 48 mm Pyropanel FR doorsets.

Hardware Item	FRL of Pyropanel Doorsets	
	38 mm FR	48 mm FR
KAS LMS-Platinum with ML-S, ML-V or ML-K mortice lock bodies. Mortice finishing plates 25 mm or 28 mm wide	-/60/30	-/60/30
KAS LMS-Platinum with ML-S, ML-V or ML-K mortice lock bodies. Mortice finishing plates 25 mm, 28 mm, 32 mm or 38 mm wide	N/A	-/60/30
KAS LMS-Platinum with NTL060, NTL070 or NTL127 tubular lock bodies	-/120/30	-/120/30
KAS NEO with ML-K, ML-S or ML-V mortice lock bodies. Mortice finishing plates 25 mm or 28 mm wide	-/120/30	-/120/30
KAS NEO with ML-K, ML-S or ML-V mortice lock bodies. Mortice finishing plates 25 mm, 28 mm, 32 mm or 38 mm wide	N/A	-/120/30
KAS NEO with NTL060, NTL070 or NTL127 tubular lock bodies	-/120/30	-/120/30

Orientation: Fire exposure from either side.

A full description of the test specimen and the test results are given in BRANZ Test Reports and Assessments:

BRANZ Fire Assessment Report FC18729-01-1

Conditions of laboratory registration by IANZ do not allow assessments by the Registered Laboratory to be covered by IANZ.

Regulatory authorities are advised to examine test reports before approving any product.

Certificate issued: 16 February 2026

Certificate Number: FC18729-01-C1-1

Certificate expiry: 16 February 2036

P. Chapman
Senior Fire Testing Engineer
For BRANZ Limited



This Laboratory is accredited by International Accreditation New Zealand (IANZ). The tests reported herein have been performed in accordance with the laboratory's scope of accreditation.

The National Association of Testing Authorities (NATA) and International Accreditation New Zealand (IANZ) are both signatories of the ILAC Mutual Recognition Agreement.

The following statement is required by the test standard "This certificate is provided for general information only and does not comply with the regulatory requirements for evidence of compliance."